

Sec. 5-83. - Amendments to published code.

The following portions of the 2009 International Plumbing Code are hereby amended:

- (1) *Section 1003.3.4.1 Grease Interceptor Capacity* is amended to read as follows:

Section 1003.3.4.1 Grease Interceptor Capacity. Grease Interceptor shall have the grease retention capacity indicated by total fixture units from Table 1003.3.4.1 and in accordance with the following:

$$\text{Total DFU's} \times 7.5 \text{ GPM} \times 12 \text{ MRT} = \text{IC/g}$$

Where:

DFU's = Drainage Fixture Units as indicated by footnote (b) in Table 1003.3.4.1

GPM = Flow rate of Gallons per minute

MRT = Minutes retention time

IC/g = Interceptor Capacity in gallons

- (2) Table 1003.3.4.1 is amended as follows:

Table 1003.3.4.1  
Capacity of Grease Interceptor(a)

Description(b)	Fixture units each
1, 2, or 3 compartment sink	3
Dishwasher	6
Garbage grinder	4
Wok-stove	4
Floor drains	3
Floor sinks	3

- a. Grease interceptors shall be minimum 250 gallon and maximum 2,000-gallon per individual unit or by an approved engineer design.
- b. Only those fixtures in use in the food preparation/clean up area shall be counted.

(Ord. No. 2003-1, § 2, 2-4-03; Ord. No. 2011-22, § 4, 8-2-11)